



NOTE:

1. WHERE FIRE HYDRANT IS SHOWN BEHIND SIDEWALK, SET CENTER OF HYDRANT 2'-0" BEHIND WALK.

APPROVED: SCOTT THOMASSON
REV. DATE: JULY 1, 2000

WATER/WASTEWATER DIVISION



STANDARD DETAILS

FIRE HYDRANT ASSEMBLY

FILE SD713.DWG DRAWING NO. **713**